

# PLAN VIEW:

SCALE: 1"=20'  
ZONING DISTRICT: RESIDENCE B

## LEGEND

F.F.=FIRST FLOOR  
T.C.=TOP OF CONC. FOUNDATION  
B.F.=BASEMENT FLOOR  
G.F.=GARAGE FLOOR  
C/O=CLEANOUT  
LRB=LONG RADIUS BEND

- ① PROPOSED 15,000 GAL SEPTIC TANK #1
- ② PROPOSED 9,000 GAL SEPTIC TANK #2 W/ FAST SYSTEM
- ③ PROPOSED 19,000 GAL DOSING CHAMBER
- ④ PROPOSED HYDRAULIC UNIT (SUPPLIED BY OAKSON, INC.)

**ADD**  
ZONE 4 (25' X 80')  
ZONE 5 (28' X 46')  
ZONE 6 (8' X 80')  
TOTAL ADDITIONAL AREA 3,928 SF  
ADDITIONAL FLOW = 3,928 X 0.68 = 2,671 GPD / 165 PER BEDROOM = 16 ADDITIONAL BEDROOMS  
16 BEDROOMS X 110 = 1,760 GPD  
WILL REQUIRE AN ADDITIONAL WELL WITH A ZONE I OF 158' AND AN IWPA OF 454'

**MARKED UP PLAN BY HANCOCK**  
SHOWING EXPANSION FOR EXISTING DRIP DISPERSAL SYSTEM. EXPANSION WOULD ALSO INCLUDE ADDITIONAL SEPTIC TANKS AND MODIFICATION TO PUMP SYSTEM.

**HANCOCK ASSOCIATES**  
PLAN REFERENCE AS-BUILT BY STAMPSKI & MCNARY.

